



Deutsche  
Akkreditierungsstelle  
D-ZE-11321-01-00



Product Service

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

**Holder of Certificate:** **Shanghai Sieyuan Watten Technology Co., Ltd.**

Room 306, Building 1, HuaNing Road - No.3399  
Minhang District  
201108 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Product:**

**PV inverter  
Hybrid Inverter**

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: [www.tuv-sud.com/ps-cert](http://www.tuv-sud.com/ps-cert)

**Test report no.:** 5040923019204-00

**Date,** 2023-08-24

( Zhengdong Ma )



Deutsche  
Akkreditierungsstelle  
D-ZE-11321-01-00



Product Service

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

## Model(s):

SiH-5kW-TH, SiH-6kW-TH, SiH-8kW-TH, SiH-10kW-TH,  
SeH-5kW-TH, SeH-6kW-TH, SeH-8kW-TH, SeH-10kW-TH,  
StH-5kW-TH, StH-6kW-TH, StH-8kW-TH, StH-10kW-TH

## Parameters:

Please see pages 3 to 9.

## Applicable standards:

VDE-AR-N 4105:2018  
DIN VDE V 0124-100 (VDE V 0124-100):2020



Deutsche  
Akkreditierungsstelle  
D-ZE-11321-01-00



Product Service

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

Model	SiH-5kW-TH, SeH-5kW-TH, StH-5kW-TH	SiH-6kW-TH, SeH-6kW-TH, StH-6kW-TH	SiH-8kW-TH, SeH-8kW-TH, StH-8kW-TH	SiH-10kW-TH, SeH-10kW-TH, StH-10kW-TH
<b>PV Input</b>				
Max. input power	7500 W	9000 W	12000 W	15000 W
Max. input voltage			1000 Vd.c.	
MPPT voltage range	150, ..., 950 Vd.c		200, ..., 950 Vd.c	
Max. input current		16/16 Ad.c.		16/32 Ad.c.
Short circuit current		20/20 Ad.c.		20/40 Ad.c.
<b>AC Output</b>				
Rated voltage		3/N/PE~ 230/400 V		
Rated frequency		50 Hz		
Rated active power	5000 W	6000 W	8000 W	10000 W
Max. apparent power	5500 VA	6600 VA	8800 VA	11000 VA
Max. current	8.4 Aa.c.	10 Aa.c.	13.3 Aa.c.	16.7 Aa.c.
Power factor		0.8leading, ..., 1, ..., 0.8lagging		



# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

## E.4 Unit certificate

<b>Unit certificate</b>	No. 5040923019204-00	
<b>Manufacturer</b>	Shanghai Sieyuan Watten Technology Co., Ltd. Room 306, Building 1, HuaNing Road - No.3399 Minhang District, 201108 Shanghai, PEOPLE'S REPUBLIC OF CHINA	
<b>Power generation unit type</b>	<p>[Inverter]:            SiH-5kW-TH, SiH-6kW-TH, SiH-8kW-TH, SiH-10kW-TH,            SeH-5kW-TH, SeH-6kW-TH, SeH-8kW-TH, SeH-10kW-TH,            StH-5kW-TH, StH-6kW-TH, StH-8kW-TH, StH-10kW-TH            Remark: certified on representative model SiH-10kW-TH of family design products,            results of the measurement of SiH-10kW-TH can be transferred to the other models            based on transferability rule of measurements in DIN VDE V 0124-100 (VDE V            0124-100):2020.</p>	
<input checked="" type="checkbox"/> Inverter	<input type="checkbox"/> Asynchronous generator	<input type="checkbox"/> Synchronous generator
<input type="checkbox"/> Stirling generator	<input type="checkbox"/> Fuel cell	<input type="checkbox"/> others
<b>Assessment values</b>	Max. active power $P_{E\max}$	10.04 kW (for model SiH-10kW-TH)
	Max. apparent power $S_{E\max}$	11.21 kVA (for model SiH-10kW-TH)
	Rated voltage	3/N/PE~, 230/400 V
<b>Rated values</b>	Rated current (AC) $I_r$	7.2 A (for model SiH-5kW-TH, SeH-5kW-TH,StH-5kW-TH) 8.7 A (for model SiH-6kW-TH, SeH-6kW-TH,StH-6kW-TH) 11.6 A (for model SiH-8kW-TH, SeH-8kW-TH,StH-8kW-TH) 14.5 A (for model SiH-10kW-TH, SeH-10kW-TH,StH-10kW-TH)
<b>Rated values</b>	Initial short-circuit current $I_k''$	8.4 A (for model SiH-5kW-TH, SeH-5kW-TH,StH-5kW-TH) 10.0 A (for model SiH-6kW-TH, SeH-6kW-TH,StH-6kW-TH) 13.3 A (for model SiH-8kW-TH, SeH-8kW-TH,StH-8kW-TH) 16.7 A (for model SiH-10kW-TH, SeH-10kW-TH,StH-10kW-TH)
<b>Network connection rules</b>	<b>VDE-AR-N 4105:2018-11/Corrigendum 1:2020-10</b> Generators connected to the low-voltage distribution network - Technical requirements for the connection to and parallel operation with low-voltage distribution networks.	
<b>Test requirement</b>	<b>DIN VDE V 0124-100 (VDE V 0124-100):2020-06 "Network integration of power generation system – Low voltage"</b> Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network.	
The above mentioned power generation unit meets the requirements of VDE-AR-N 4105.		



Deutsche  
Akkreditierungsstelle  
D-ZE-11321-01-00



Product Service

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

## E.5 Test report "Network interactions" for generating units with an input current > 75 A

Extract from test report for unit certificate "Determination of electrical properties"		<u>No. 5040923019204-00</u>
Generation unit manufacturer:	Shanghai Siyuan Watten Technology Co., Ltd. Room 306, Building 1, HuaNing Road - No.3399 Minhang District, 201108 Shanghai, PEOPLE'S REPUBLIC OF CHINA	
Manufacturer indications:	Type of system	Inverter for PV system
	Max. active power P <sub>Emax</sub>	5000 W (for model SiH-5kW-TH, SeH-5kW-TH,StH-5kW-TH) 6000 W (for model SiH-6kW-TH, SeH-6kW-TH,StH-6kW-TH) 8000 W (for model SiH-8kW-TH, SeH-8kW-TH,StH-8kW-TH) 10000 W (for model SiH-10kW-TH, SeH-10kW-TH,StH-10kW-TH)
	Rated voltage	3/N/PE~, 230/400 V
Period of measurement:	From 2023-02-14 to 2023-08-06	

Flicker (EN 61000-3-3) (SiH-10kW-TH )					
Test condition	d <sub>(t)</sub> - 500ms [%]	d <sub>c</sub> [%]	d <sub>max</sub> [%]	P <sub>st</sub>	P <sub>lt</sub>
Continuous operation	0/0/0	0/0/0	0.750/1.220/0.650	0.070/0.080/0.080	0.070/0.080/0.080
Start	0/0/0	1.20/0.45/0.47	1.21/0.51/0.52	-	-
Stop	0/0/0	1.43/1.00/1.01	1.63/1.23/1.23	-	-
Limit	3.3%	3.3%	4%	1.0	0.65



# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

Harmonics (IEC 61000-3-2)(SiH-10kW-TH )												
Power P/Pn[%]	0-5	10	20	30	40	50	60	70	80	90	100	Limit
Ordinal number	A	A	A	A	A	A	A	A	A	A	A	A
2	0.154	0.079	0.165	0.218	0.209	0.216	0.219	0.012	0.037	0.025	0.124	1.080
3	0.116	0.260	0.303	0.168	0.108	0.129	0.138	0.163	0.159	0.138	0.138	2.300
4	0.140	0.256	0.141	0.123	0.105	0.124	0.150	0.105	0.114	0.118	0.143	0.430
5	0.100	0.132	0.062	0.063	0.055	0.082	0.120	0.143	0.154	0.189	0.129	1.140
6	0.073	0.055	0.104	0.082	0.068	0.025	0.028	0.028	0.036	0.033	0.048	0.300
7	0.081	0.069	0.091	0.045	0.056	0.079	0.081	0.075	0.073	0.076	0.053	0.770
8	0.068	0.069	0.060	0.089	0.091	0.065	0.037	0.031	0.045	0.055	0.042	0.230
9	0.057	0.049	0.053	0.082	0.055	0.032	0.028	0.042	0.059	0.071	0.040	0.400
10	0.029	0.036	0.081	0.048	0.039	0.045	0.034	0.027	0.027	0.023	0.022	0.184
11	0.070	0.067	0.066	0.041	0.053	0.036	0.030	0.046	0.046	0.047	0.022	0.330
12	0.037	0.039	0.033	0.029	0.042	0.045	0.036	0.021	0.018	0.021	0.038	0.153
13	0.059	0.041	0.027	0.054	0.051	0.043	0.037	0.042	0.050	0.051	0.051	0.210
14	0.027	0.024	0.018	0.045	0.023	0.041	0.049	0.025	0.015	0.021	0.020	0.131
15	0.055	0.047	0.043	0.051	0.039	0.044	0.031	0.022	0.032	0.036	0.023	0.150
16	0.016	0.013	0.023	0.025	0.020	0.029	0.020	0.023	0.028	0.035	0.039	0.115
17	0.059	0.053	0.065	0.041	0.055	0.046	0.049	0.045	0.041	0.042	0.036	0.132
18	0.014	0.016	0.018	0.035	0.024	0.037	0.028	0.026	0.033	0.034	0.072	0.102
19	0.055	0.042	0.034	0.044	0.052	0.048	0.048	0.042	0.034	0.040	0.041	0.118
20	0.017	0.017	0.022	0.021	0.029	0.031	0.041	0.026	0.031	0.037	0.054	0.092
21	0.050	0.045	0.045	0.053	0.036	0.051	0.040	0.045	0.037	0.035	0.035	0.107
22	0.026	0.029	0.043	0.031	0.041	0.032	0.044	0.034	0.031	0.039	0.061	0.084
23	0.042	0.045	0.053	0.045	0.038	0.048	0.040	0.045	0.040	0.035	0.026	0.098
24	0.032	0.038	0.037	0.037	0.034	0.037	0.040	0.041	0.028	0.034	0.070	0.077
25	0.038	0.035	0.029	0.030	0.047	0.035	0.042	0.043	0.042	0.037	0.024	0.090
26	0.038	0.038	0.034	0.036	0.040	0.045	0.039	0.047	0.037	0.032	0.050	0.071
27	0.033	0.032	0.034	0.042	0.046	0.024	0.043	0.045	0.045	0.050	0.044	0.083
28	0.040	0.039	0.047	0.043	0.042	0.040	0.044	0.044	0.043	0.033	0.040	0.066
29	0.023	0.025	0.032	0.037	0.031	0.030	0.038	0.038	0.047	0.049	0.035	0.078
30	0.043	0.036	0.035	0.034	0.035	0.030	0.042	0.035	0.040	0.030	0.051	0.061
31	0.016	0.016	0.025	0.026	0.025	0.041	0.033	0.034	0.043	0.048	0.033	0.073
32	0.042	0.037	0.031	0.029	0.031	0.041	0.036	0.034	0.043	0.042	0.035	0.058
33	0.013	0.011	0.026	0.030	0.038	0.043	0.029	0.041	0.044	0.053	0.039	0.068
34	0.045	0.036	0.035	0.042	0.046	0.045	0.032	0.031	0.042	0.047	0.025	0.054
35	0.015	0.014	0.024	0.040	0.044	0.038	0.036	0.042	0.046	0.057	0.051	0.064
36	0.044	0.034	0.028	0.034	0.039	0.034	0.031	0.028	0.028	0.031	0.023	0.051
37	0.019	0.017	0.030	0.035	0.032	0.031	0.042	0.040	0.038	0.049	0.053	0.061
38	0.047	0.037	0.027	0.023	0.025	0.027	0.033	0.033	0.027	0.036	0.025	0.048
39	0.023	0.019	0.031	0.037	0.028	0.031	0.035	0.037	0.032	0.039	0.030	0.058
40	0.042	0.036	0.029	0.027	0.021	0.028	0.032	0.025	0.025	0.031	0.020	0.046

Max. value of three phase are recorded for harmonics



Deutsche  
Akkreditierungsstelle  
D-ZE-11321-01-00



Product Service

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

## E.6 Certificate of the network and system protection

<b>Certificate of NS protection</b>	No. 5040923019204-00	
<b>Manufacturer</b>	Shanghai Sieyuan Watten Technology Co., Ltd. Room 306, Building 1, HuaNing Road - No.3399 Minhang District, 201108 Shanghai, PEOPLE'S REPUBLIC OF CHINA	
<b>Type of NS protection</b>		
<b>Central NS protection</b>	<input type="checkbox"/>	
<b>Integrated NS protection</b>	<input checked="" type="checkbox"/>	Assigned to power generation unit type 5000 W (for model SiH-5kW-TH,SeH-5kW-TH,StH-5kW-TH) 6000 W (for model SiH-6kW-TH,SeH-6kW-TH,StH-6kW-TH) 8000 W (for model SiH-8kW-TH,SeH-8kW-TH,StH-8kW-TH) 10000 W (for model SiH-10kW-TH,SeH-10kW-TH,StH-10kW-TH)
<b>Network connection rules</b>	<b>VDE-AR-N 4105:2018-11/Corrigendum 1:2020-10</b> Generators connected to the low-voltage distribution network - Technical requirements for the connection to and parallel operation with low-voltage distribution networks.	
<b>Test requirement</b>	<b>DIN VDE V 0124-100 (VDE V 0124-100):2020-06 "Network integration of power generation system – Low voltage"</b> Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network.	
The network and system protection mentioned above meets the requirements of VDE-AR-N 4105.		

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

## E.7 Requirement for the test report for the NS protection

<b>Extract from test report for NS protection</b> "Determination of electrical properties"		No. 5040923019204-00			
<b>NS protection test report</b>					
Type of NS system:	Integrated NS protection	<b>Other Manufacturer indications</b>			
Software version:	MDSP: 01.003, SDSP: 01.001, ARM: 01.002				
Manufacturer:	<u>Shanghai Sieyuan Watten Technology Co., Ltd.</u> <u>Room 306, Building 1, HuaNing Road - No.3399 Minhang District, 201108</u> <u>Shanghai, PEOPLE'S REPUBLIC OF CHINA</u>				
Measuring period:	From 2023-02-14 to 2023-08-06				
		<b>Inverter</b>			
		directly coupled synchronous and asynchronous generators with $P_n > 50 \text{ kW}$			
Protection function	Setting value	Tripping value	Break time NS protection *		
Rise-in-voltage protection $U >>$	$1.25 * U_n$	L1-N/L2-N/L3-N: 288 V, 288 V, 288 V, L1-N: 290 V, L2-N: 288 V, L3-N: 289 V,	L1-N/L2-N/L3-N: 115 ms, L1-N: 108 ms, L2-N: 103 ms, L3-N: 102 ms,		
Rise-in-voltage protection $U >$	$1.10 * U_n$	$1.0 * U_n$	ms**		
Voltage drop protection $U <$	$0.8 * U_n$	L1-N/L2-N/L3-N: 183 V, 184 V, 184 V, L1-N: 184 V, L2-N: 183 V, L3-N: 184 V,	L1-N/L2-N/L3-N: 3016 ms, L1-N: 3036 ms, L2-N: 3038 ms, L3-N: 3029 ms,		
Voltage drop protection $U <<$	$0.45 * U_n$	L1-N/L2-N/L3-N: 102 V, 102 V, 102 V, L1-N: 103 V, L2-N: 103 V, L3-N: 103 V,	L1-N/L2-N/L3-N: 316 ms, L1-N: 306 ms, L2-N: 319 ms, L3-N: 314 ms,		
Frequency decrease protection $f <$	47.5 Hz	47.47 Hz	110 ms		
Frequency increase protection $f >$	51.5 Hz	51.48 Hz	104 ms		
*: The tripping time includes the period from the limit value violation $U/f$ until the tripping signal to the interface switch.					
When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.					
The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms.					
**: Verification disconnection time of moving 10-min-average value.					
Disconnecting time as below:					
1. 496 s (L1-N) / 496 s (L2-N) / 497 s (L3-N) (from 600s@ $U_n$ to 112% $U_n$ ) 2. Continuous operation (L1-N/L2-N/L3-N) (from 600s@ $U_n$ to 108% $U_n$ ) 3. 301 s (L1-N) / 302 s (L2-N) / 303 s (L3-N) (from 600s@106% $U_n$ to 114% $U_n$ )					



Deutsche  
Akkreditierungsstelle  
D-ZE-11321-01-00



Product Service

# Certificate of Conformity

No. ESY 120194 0012 Rev. 00

<input checked="" type="checkbox"/> as integrated NS protection	
Assigned to power generation unit type	5000 W (for model SiH-5kW-TH,SeH-5kW-TH,StH-5kW-TH) 6000 W (for model SiH-6kW-TH,SeH-6kW-TH,StH-6kW-TH) 8000 W (for model SiH-8kW-TH,SeH-8kW-TH,StH-8kW-TH) 10000 W (for model SiH-10kW-TH,SeH-10kW-TH,StH-10kW-TH)
Integrated interface switch type	Series-connected relays for both line and neutral conductors Relay type: HF161F-W-12-HT(704)
Response time of interface switch for integrated NS protection	Release time: Max. 10 ms
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.	<input checked="" type="checkbox"/>